

QwikSmoke™

QT2330

QwikSmoke™

Universal Smoke Alarm Test Gas

For use with all smoke detectors.

- ▶ Functionally Tests **Any Type of Smoke Detector.**
- ▶ Fast. Reliable. and Easy to Use...
Takes Less Than 30 Seconds!*
(*for Most Detectors)
- ▶ Non-Flammable
- ▶ No CFCs • No Silicone
- ▶ No Phthalate Esters

1. Shake well before using.

NOTE: If you use a third-party dispensing device, follow the instructions provided with the dispenser.

2. Extinguish any nearby open flames, cigarettes, or candles. Contents can be ignited, do not smoke or use near open flames.
3. Depress the spray actuator completely to begin spraying the contents of the can at the smoke detector from a distance of approximately 2-3 feet. Discharge for 0.5-1 second, repeating every 10 seconds for 60 seconds or until alarm sounds. You don't need to use the entire can. If the alarm does not sound, the alarm is not functional and should be replaced.

For more details or information about QwikSmoke™ or Qwik CO™ visit www.qwik.com

QwikProducts™, Qwik CO™ and QwikSmoke™ are trademarks of Mainstream Engineering Corporation. Rockledge, Florida 32955, (321) 631-3550 • All QwikProducts™ are made in the USA.



SIGNALING



FIRE ALARM
EQUIPMENT
S35537



CAUTION: Contents under pressure. See all cautions on back panel.



Mainstream Engineering Corporation
1-800-866-3550
www.qwik.com