

KEY QUALITIES



ULTRA-DURABLE

UV-resistant, high-durability construction. Includes 304 Stainless Steel, 13 Guage Tie-Down Assemblies to secure the outdoor unit to the QwikPad®.

LIGHT-WEIGHT

Our 36" x 36" pad weighs only 29 lbs for transport, but 163 lbs once filled.

The 40" x 40" pad weighs just **35 lbs** for transport, but 203 lbs filled.



HURRICANE-RATED

Rated for winds up to 180 mph and exceeds Miami-Dade 175 mph wind requirements.



UNIQUE GELLING AGENT

Once water is added, a super absorbent material forms a **solidus gel**, making the pad weigh about **5X** its initial weight to meet building code requirements.

FINALLY, A LIGHTWEIGHT, EASY-TO-INSTALL CONDENSER PAD THAT MEETS WIND LOADING REQUIREMENTS

INCLUDED HARDWARE:

 $\bigcirc \bigcirc \bigcirc \bigcirc$



Carriage Bolt Holder (4)











Water Fill Plug







VISIT OUR WEBSITES www.qwik.com www.epatest.com



MADE IN THE US MKTG000243 REV-L





QWIKPAD[®] FOR CONDENSERS Rated for 180 mph Hurricane Winds

The Florida building code rated air conditioning support pad is lightweight when purchased, but weighs enough to meet code requirements up to 180 mph wind loading when filled with water and secured with stainless steel tie-down assemblies (supplied). Each pad includes a unique gelling agent that, once water is added, forms a solidus gel. Optional ground and concrete anchors provide additional hurricane protection when needed.

FLORIDA BUILDING CODE NOTICE

This product meets the following building code requirements:

- 1. Mechanical Vol., Sect. 304.10 Clearances from Grade This product provides 4" of clearance above adjoining grade.
- 2. Mechanical Vol., Sect. 301.15 Wind resistance Load combinations in accordance with the Florida Building Code, Building Vol. Ch. 16 and ASCE 7 Ch. 2.

Wind pressure calculations performed per Florida Building Code, Building Vol. - Ch. 16 and ASCE 7 - Ch. 29. For the most up-to-date documentation, visit our website, **www.qwik.com/qwikpad-for-condensers-product-details/** or call **1-800-866-3550**.

TO INSTALL THE UNIT:

- Choose acceptable equipment pad size and anchoring method that meets wind loading requirements in your area. Use the load tables included with the QwikPad[®] for Condensers or go to www.qwik.com/ qwikpad-for-condensers-product-details/ to use our automated calculation software.
- 2. Tip pad towards fill port corner. This will cause gelling agent to collect near fill port for proper distribution when filling.
- 3. Level the pad on the ground.
- 4. Fill pad completely with tap water. Water will solidify into gel over time.
- 5. Install concrete or ground anchors, when required.
- 6. Secure the equipment to the pad using tie-down assembly hardware.

SPECIFICATIONS	QT8036	QT8040
DIMENSIONS	36" x 36" x 4"	40" x 40" x 4"
MATERIAL	Linear Low Density Polyethylene (LLDPE)	Linear Low Density Polyethylene (LLDPE)
PAD WEIGHT (EMPTY)	29 lb	35 lb
PAD WEIGHT (FULL)	163 lb	203 lb
MAXIMUM CONDENSING UNIT SIZE	32" x 32"	36" x 36"
MINIMUM CONDENSING UNIT SIZE*	22" x 22" (Listed on Engineering Documents) 20.5" x 20.5"	24" x 24" (Listed on Engineering Documents) 17.5" x 21.5"

*An independent Engineering Report is recommended to verify proper installation, as mounting requirements may vary when accommodating mini-splits.

OPTIONAL ACCESSORIES Anchors may be required to meet high wind loading, depending on the unit size and weight. Use the load tables included with the Qwik**Pad**® for **Condensers** or go to our website to use our automated calculation software to determine if anchors are necessary for your installation.

GROUND ANCHOR KIT (PKG OF 2)

OT8110







QwikProducts® and QwikPad® are registered trademarks of Mainstream Engineering Corporation

Rockledge, Florida 32955, (321) 631-3550 © 2025 Mainstream Engineering Corporation

Protected by U.S. Patent #10,408,493, #10,559,742, #11,322,678, and #11,362,262



VISIT OUR WEBSITES www.qwik.com www.epatest.com

